

GOVERNMENT OF TELANGANA STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT



Ack. No.:	RENEWAL of NO OBJECTION CERTIFICATE					
NOC:	198320002019 Issue Date : 12/07/2019				EMPIN /F	
	0006551/RENEWAL/Warangal - Urban/2019					
NOC TYPE:	RENEWAL*					
Valid Upto:	11-07-2024					
Applicant Details:	NarayanaReddy,9391556601,St.Peters Educational					
	Association, H.NO.2-4-1211. Vidyanagar, T.V. Tower, Hanamkonda.					
Building for which	St.Peters Educational Association, St.Peters Educational Association, H.NO.2-4-1211. Vidyanagar, T.V. Tower, Hanamkonda./-Hanamkonda/Hanamkonda/Warangal - Urban					
NOC issued:	11211.Vidyanaga	r, T.V.Tower Han	amkonda./-Hana	amkonda/Hanamkon	da/Warangal - Urban	
Concessions in Setback	ks Given in Lieu o	f Land	No			
Surrendered in Road W	/idening:		INO			
	3000.00	Height (Metres)	: 10.00			
Open Spaces (Metres):	North: (F) 6.00	South: 1.00	East: 6.00	West: 3.00		
No. of Floors: 0 Cellars, 0 Stilts, 1 Ground, 2 Floors, 0			Occupancy	EDUCATIONAL B-1 Schools up to		
Terrace			Type:	senior secondary level		
Total Built-up Area	2643.00			No. of Staircase		
(Sq.Mtrs):	2043.00			Required/Propos	12	
Fees Paid (₹):	10000		Staircases:	Aggregate Widtl Required/Propos (Metres):	dth	
				1		
F	Fighting Installati	ions Provided as	per Table 23, P	art-IV of NBC, 200	05:	
Fire Extinguisher:	15	First Aid Hose Reel:	6	Wet Riser:	0	
Down Comer:	0	Yard Hydrant:	0	Automatic Sprinkler System:	0	
Manually Operated Electronic Fire Alarm Systems:	0	Terrace Tank (Litres):	10000			
Automatic Detection and Alarm System:	0	Underground Static Water Storage Tank (Litres):	10000			
Pump Near						
Underground Static	Type	lO _{II}	antity	(Capa	aite in Liteachain)	
Water Storage Tank	Electrical	0			city in Litres/min)	
(Fire Pump) with	Diesel 0		0			
Minimum Pressure of	Jockey 0		0			
3.5 kg/cm2 at Terrace	Joency	IV		U		
Level						
Fire Pump at the						
	(Capacity in Liti	res/min)			The state of the s	
	450					
Pressure of 2.0 kg/cm2						
"THIS IS COMPUTER	GENERATED DO	DCUMENT AND	DO NOT REO	UIRE ANY STAME	OR SIGNATURE"	
** For details and condit	ions of Renewal N	lo Objection Certi	ficate for Occur	oancy, refer overlent	or diolari ord	

St. Peter's & du School Vidyanagar, Hanamkonda, Warangal District T.S.

St. Peter's edu School Vidyanagar, Hanamkonda, Warangal District T.S